



269-2014 ADDENDUM 2

THE DESIGN AND CONSTRUCTION OF THE WYPER ROAD STORAGE FACILITY

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE REQUEST FOR PROPOSAL

ISSUED: April 30, 2014
BY: Greg Kucel
TELEPHONE NO. (204) 986-3429

THIS ADDENDUM SHALL BE INCORPORATED INTO THE REQUEST FOR PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: Ar20131129

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Request for Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Proposal may render your Proposal non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg Time, May 5, 2014.

PART E – SPECIFICATIONS

Revise: E3.1(c) to read: The City of Winnipeg will pay for the electrical and telephone supply service to the facility. Contractor shall coordinate their work with Manitoba Hydro & MTS.

Add: E3.1 (e) The Storage Facility does not require additional humidity control beyond the capabilities of the Air Conditioning System.

Add: E3.1 (f) Contractor shall carry a \$15,000 cash allowance for the Storage Facility's Intrusion System.