



668-2014 ADDENDUM 1

ART MCOUAT MEMORIAL PARK – ATHLETIC FIELD RE-DEVELOPMENT

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: Ken Rech
BY: Aug. 1, 2014
TELEPHONE NO. (204) 489-6616

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20131129

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

- Revise: E16.2(b) to read: The two (2) soccer fields will be connected to a new summer water service pit, which will be installed near the north property line, along Maginot Street. The new water **50** mm dia. water service and pit enclosure is part of the Contractor's Work and must be installed in accordance with SD-241B and to C.W. 3530-R3.
- Revise: E16.4(k) to read: Double check valve: shall be **"Watts 50 mm 007 Double Check Valve"**. This valve is for the summer water service located in the summer service enclosure.
- Revise: E16.5(b) to read: The Contractor shall install a new **50** mm diameter summer water service water supply for the soccer field irrigation systems, in accordance with SD-241 B and as per CW 3530-R3. This water service shall include a double check valve and water meter and be located as per drawing 1-L4.

DRAWINGS

Replace: 668-2014 _Drawing_L4 with 668-2014 _Addendum_1 Drawing L4-R1