

CONSTRUCTION STANDARDS

TO BE CONSTRUCTED IN ACCORDANCE WITH MANITOBA HYDRO
DISTRIBUTION AND SUBTRANSMISSION STANDARDS, LATEST REVISION.
NO MAJOR CHANGE SHALL BE MADE WITHOUT APPROVAL OF THE DESIGN
ENGINEER OR DELEGATE.

CITY OF WINNIPEG REQUIREMENTS:

WATER AND WASTE DEPARTMENT APPROVAL SUBJECT TO THE FOLLOWING NOTES:

A MINIMUM CLEARANCE OF 1000 MILLIMETERS SHALL BE PROVIDED BETWEEN THE UNDERSIDE OF ANY EXISTING WATERMAIN OF SEWERMAIN PIPE AND THE TOP OF THE PROPOSED WORKS

OR
A MINIMUM CLEARANCE OF 500 MILLIMETERS SHALL BE PROVIDED
BETWEEN THE UNDERSIDE OF THE PROPOSED WORKS AND THE TOP OF
ANY EXISTING WATERMAIN OR SEWERMAIN PIPE

A MINIMUM LATERAL CLEARANCE OF 1.0 METER SHALL BE PROVIDED BETWEEN THE NEAREST EDGE OF THE PROPOSED WORKS AND THE NEAREST EDGE OF ANY EXISTING WATERMAIN, WATERMAIN VALVE, HYDRANT, SEWERMAIN OR SEWER MANHOLE.






A MINIMUM CLEARANCE OF 3.0 METERS SHALL BE PROVIDED

FOR CLEARANCE OF EXISTING WATER & WASTE
DEPARTMENT PLANT CONTACT THE SURVEY &
INSPECTION BRANCH 48 HOURS PRIOR TO
CONSTRUCTION AT 986-3322

PROPOSED SEQUENCE OF CONSTRUCTION:

- MH STAFF SHALL DISCONNECT AND ISOLATE THE EXISTING STREET LIGHT POLE OR POLES TO BE REPEARED.
- CONTRACTOR TO INSTALL TEMPORARY O/H FEEDS BETWEEN EXISTING POLES.
- MH STAFF TO INSTALL FINAL DROP FROM EXISTING POLE TO SOURCE AND ENERGIZE.
- CONTRACTOR TO INSTALL NEW POLES, UNDERGROUND STREET LIGHT CABLE (EVEN POLES), GROUND RODS, RELAYS, AND BOTTOM SECTION OF CABLE GUARD AT DIP (IF APPLICABLE) AND TERMINATE IN HAND HOLE.
- MH STAFF TO DISCONNECT AND ISOLATE TEMPORARY O/H FEED TO EXISTING POLES, AS WELL AS COMMISSION AND ENERGIZE NEW POLES FROM NEW UNDERGROUND SOURCE.
- CONTRACTOR TO REMOVE O/H FEEDS AND REMOVE EXISTING POLES.

CONTACT	NAME	PHONE
DESIGN	MIKE PARTYKA	360-4475
DISTRICT ENG TECH	ROB DENENKA	235-4355
ENERGY SERVICES ADVISOR	TERRY MCCARTHY	360-4127
U/G CONSTRUCTION	JAYSON WITT	803-1165
O/H CONSTRUCTION	WAYNE IRELAND	360-5786
CUSTOMER CONTRACT	RICK PHILLIPS	360-7018
CONNECTIONS	ALVARO SILVA	360-6214
TEMP. STRINGING	TERRY TABAK	360-7521

MAGENTA		PROPOSED TRENCH
RED		PROPOSED OBJECT
PINK		OBJECT TO BE ABANDONED
GREEN		OBJECT TO BE SALVAGED
BLACK		EXISTING OBJECT
LL * ANNOTATION		1 - 16" AL CH STREET LIGHTING CABLE
LL * ANNOTATION		1 - 1/0 TRIPLEX STREET LIGHTING CABLE

COW TENDER
2014-R-06

NOTE: INDICATION OF ALL UNDERGROUND UTILITIES IS FOR ILLUSTRATIVE PURPOSES ONLY. CONTACT THE APPLICABLE UTILITIES FOR SPECIFIC PLANT LOCATIONS AND CLEARANCES.

INFORMATION PERTAINING TO THE SIZE AND LOCATION OF MANITOBA HYDRO FACILITIES AND INSTALLATIONS IS ILLUSTRATIVE AND SHOULD NOT BE RELIED ON FOR THE PURPOSES OF ANY ACTIVITY BEING CONDUCTED AT OR NEAR THE FACILITY AND/OR INSTALLATION. ALL LOCATIONS AND EQUIPMENT MUST BE IDENTIFIED BY APPROPRIATE HYDRO DISTRICT OFFICES PRIOR TO ANY PHYSICAL ACTIVITY UNDERTAKEN AT OR NEAR HYDRO INSTALLATIONS. A CURRENT WORK CLEARANCE REQUEST FORM CAN BE OBTAINED FROM THE DISTRICT OFFICE AND MUST BE ON SITE PRIOR TO THE COMMENCEMENT OF ANY EXCAVATIONS.

CALL BEFORE YOU DIG!!

DATE		REVISONS		BY	CKD.	APP.	AREA NUMBER 4901		MANITOBA HYDRO DISTRIBUTION PLANNING & DESIGN		
							STATION NUMBER 2637		WBS # P:22903 NETWORK # 4302335		
							FEEDER NUMBER PR644		DISTRICT: ST. BONIFACE STREET LIGHTING PROJECT - HOUE DR FROM DUCHARME AVE. TO DUCHARME AVE.		
DRAWING NUMBER		REFERENCE DRAWINGS				DRAWN MP	SYSTEM VOLTAGE 7.2/12.47 kV		CONTRACTOR TO REPLACE EXISTING UNDERGROUND STREET LIGHTING PLANT.		
						CHECK BF					
						SCALE 1:750					
						DATE 2014/02/18					
							1-04707-DD-50000-0188			SHT.	REV.
										01/02	00