


GENERAL NOTES:

- ALL DIMENSIONS ARE TO FACE OF GYPSUM BOARD OR CONCRETE OR MASONRY UNLESS OTHERWISE NOTED (DIMENSIONS TO STRUCTURAL GRIDLINES AND COLUMN CENTRELINES ARE INDICATED WITH A DOT). VERIFY DIMENSIONS AND DATA HERE IN WITH CONDITIONS ON SITE. REPORT ANY DISCREPANCY TO ARCHITECT FOR ADJUSTMENT
- ALL INTERIOR WALLS TO EXTEND TO U/S OF STEEL DECK UNLESS OTHERWISE INDICATED.
- 3. ALL INTERIOR WALLS NOT INDICATED ARE TO BE TYPE 4S2.
- 4. CAULK PERIMETER OF GYPSUM BOARD CONTINUOUSLY BOTH SIDES OF ALL FIRE SEPARATIONS AND INTERIOR WALLS CONTAINING ACOUSTIC INSULATION. 5. SUPPLY AND INSTALL FIRESTOPPING AND SMOKE SEALS AROUND ALL PENETRATIONS THROUGH FIRE SEPARATIONS TO MAINTAIN THE INTEGRITY OF THE FIRE SEPARATION.
- 6. FIRE SEPARATIONS ARE INDICATED BY LINETYPE DESIGNATION ON DRAWINGS

 REFER TO LEGEND. CONSTRUCT ALL INTERIOR FIRE SEPARATIONS TO
 MAINTAIN THE CONTINUITY OF THESE SEPARATIONS AND RATINGS. FIRE
 SEPARATIONS SHALL BE FULLY LABELLED ON THE WALL WITH 150 mm H.
 LETTERS ABOVE THE FINISHED CEILING ● 6 M. O.C.
- SOUND TRANSMISSION CLASS (STC) RATINGS HAVE BEEN QUOTED FROM THE NATIONAL BUILDING CODE OF CANADA.
- G.C. SHALL COORDINATE MECHANICAL AND ELECTRICAL WITH STRUCTURE AND ADJUST FURRING AS REQUIRED IN CONJUNCTION WITH ARCHITECT.
- 9. ALL GYPSUM BOARD TO BE "TYPE X" TO ACHIEVE FIRE AND ACOUSTIC RATINGS INDICATED ON WALL TYPES.
- EXISTING WALLS THAT ARE TO RECEIVE NEW FINISHES ARE TO BE PATCHED AND REPAIRED WHERE REQUIRED. PATCH AND REPAIR ALL EXISTING WALLS WHERE DEMOLITION OCCURS TO MATCH ADJACENT WALL FINISH.
- 11. GENERAL CONTRACTOR TO PROVIDE ALL BLOCKING REQUIRED IN WALLS TO ACCOMMODATE INSTALLATION OF MILLWORK, ARTWORK, FURNITURE WASHROOM CCESSORIES, & EQUIPMENT (IN CONTRACT, OFP & NOT IN CONTRACT).
- SUPPLY AND INSTALL 19 mm PLYWOOD BACKBOARDS (PAINT AS SPECIFIED) FOR ELECTRICAL PANELS, ETC. (REFER TO ELECTRICAL DRAWINGS FOR SIZE AND LOCATION).
- 13. REFER TO A9.1 FOR FURNITURE AND EQUIPMENT NOT INCLUDED IN
- 14. MOULD RESISTANT GYPSUM BOARD (IN LIEU OF GYPSUM BOARD INDICATED ON WALL TYPES): A. PROVIDE MOULD RESISTANT GYPSUM BOARD ON WALL SURFACES CONTAINING PLUMBING FIXTURES — FULL HEIGHT (TO MIN. 150 mm ABOVE CEILING) AND WIDTH TO ADJACENT INTERSECTING WALL(S). WHERE INTERSECTING WALL IS LESS THAN 900 mm FROM PLUMBING FIXTURE CENTERLINE, CONTINUE MOULD RESISTANT GYPSUM BOARD ONTO ADJACENT WALL SURFACE MIN. 900 mm.
- B. PROVIDE MOULD RESISTANT GYPSUM BOARD ON WALL SURFACES WITHIN WASHROOMS & JANITOR ROOMS.
- TILE BACKER BOARD TO BE USED IN LIEU OF GYPSUM BOARD INDICATED ON WALL TYPES TO EXTENT OF WALLS WHERE CERAMIC WALL TILES ARE INDICATED TO BE INSTALLED.



EXISTING PARTITION TO REMAIN EXISTING DOOR TO REMAIN

FURNITURE & EQUIPMENT NOT IN CONTRACT (NIC); PROVIDED BY SEPARATE VENDOR


CORNER GUARD, STAINLESS STEEL.

1PC: SURFACE MOUNT, 900mm H x 38mm W
SS CORNER GUARD

1 APR. 15, 2014 ISSUED FOR CONSTRUCTION

Issue / Revision MS,RH,CWG

Drawn By: Printing Date: 4/15/2014





ARCHITECTURAL

copyright in the same being reserved to them. No reproduction may be made without the permission of the architects, and when made, must bear their names. All prints to be

The contractor is to verify dimensions and data noted herein with conditions on the site and is held responsible for reporting any discrepancy to the architects for adjustment.



LM Architectural Group

500-136 Market Ave Winnipeg Manitoba Canada R3B 0P4 t: (204) **942.0681** f: (204) 943.8676 www.lm-architects.com



NEW CHARLESWOOD LIBRARY LEASED ACCOMMODATIONS 4910 ROBLIN BLVD. WINNIPEG, MANITOBA

Main Floor Plan

Comm. No.: 1402