



# 806-2014 ADDENDUM 3

## MARION AND ASSINIBOINE FLOOD PUMPING STATION VENTILATION AND ELECTRICAL UPGRADES

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY**

ISSUED: September 18<sup>th</sup>, 2014  
BY: Adam Pawlikewich  
TELEPHONE NO. (204) 896-1209

**THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS**

Template Version: A20131129

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.**

### **PART B – BIDDING PROCEDURES**

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, September 23, 2014.

### **PART E – SPECIFICATIONS**

Section 25 05 01

Revise: 1.4.4 to read: The Contractor is only responsible for termination to the terminal within the SCADA cabinet and internal wiring.

Section 25 30 01

Revise: 2.2.3 to read: Programming to be provided by the City. Contractor to coordinate all SCADA communication I/O points with City of Winnipeg.

Revise: 3.1.6 to read: Provide all configuration for all components as required. Any and all custom objects or applications that have been used in the development of the programs for all devices shall have full source code turned over to the City. There shall be no custom objects that are locked preventing the City from modifying the object and/or application. No intellectual property rights on the programs, objects or applications are permitted. City to have full access to all aspects of programs, objects and applications. Provide a hard copy of all files to be included within the O&M manuals.

Add: 3.2.3 Contractor shall arrange factory acceptance testing for control panels at panel shop. Contract Administrator will co-ordinate with the City for representatives to be present.