



TRANSIT STOP IMPROVEMENTS 2015

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: November 24, 2015
BY: Jackie Wilkie
TELEPHONE NO. 204 956-0396

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20150806

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 7 (seven) of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Add:	E14.27	Materials
	E14.27.1	Supply and Install Power Pedestal 'A' 60A/ 120/240V/ 1ø/3W with metering to MB Hydro Satisfaction
	E14.27.2	Power pedestal to be W.P, Lockable, Manco or approved equal in accordance with B7.
	E14.27.3	Supply and Install Power Pedestal 'A' in E14.27.1 to be incidental to the Supply and Install Electrical works.

DRAWINGS

Add: 1001-2015_Addendum_1-Drawings_E1-R0.pdf