

JB-09/10 LAYOUT (TYPICAL FOR JB-07/13)

JB-04 LAYOUT (TYPICAL FOR JB-05, JB-06, JB-08)

JB-01 / 03 LAYOUT


| _ | | | |
|---|---|------------------------------------------------------|-------------------------------|
| | 1 | TUBULAR ENCLOSURE HEATER 120V, 100W | TEMPCO EHT00030 |
| | 2 | CAT 6 DATA LINE SURGE PROTECTOR | DITEK POE DTK-MRJOP |
| | 3 | POE MEDIA CONVERTER CAT 6 / 1 FIBRE SC, MULTIMODE | COMNET CNFE1004APOEM |
| | 4 | FIBRE OPTIL TERMINATION BOX WALL MOUNT | FIBERTRONICS INC FOTB-6-12 |
| | 5 | UPS POWER SUPPLY, 48 VDC | FLEXNET MPS 48-7 |
| | 6 | NEMA 4 ENCLOSURE | HAMMOND MANUFACTURING EJ12126 |

METRIC

WHOLE NUMBERS INDICATE MILLIMETRES DECIMALIZED NUMBERS INDICATE METRES

APEGM Certificate of Authorization Dillon Consulting Limited (MB) No. 1789 Date: MAR. 4, 2016

| B.M. ELEV. | | | | DESIGNED BY | BLM | '', | ENGINEER'S SEAL |
|---------------|-------------------|----------|-----|----------------|----------|--------------|---------------------------|
| | | | | DRAWN BY | SCK | | March 4 1A |
| | | | | CHECKED BY | BLM | DILLON | B.L. B.L. B.L. |
| | | | | APPROVED BY | ARR | CONSULTING | PROFESSIONAL |
| | | | | HOR. SCALE | AS NOTED | RELEASED FOR | PARTITION CO. |
| 1 | ISSUED FOR TENDER | 16/03/04 | ARR | VERTICAL | | CONSTRUCTION | CONSULTANT PROJECT NUMBER |
| NO. | REVISIONS | DATE | BY | DATE | | DATE | 13-8224 |



| Zinnipeg 7 | HE CITY OF | |
|------------|---------------|---------------------|
| 4D W/I | NINIDEC DEDOT | CITY DRAWING NUMBER |

| 4R WINNIPEG DEPOT | city drawing number 1-0851A-E0008-001 | | |
|-------------------|------------------------------------------|--|--|
| PACIFIC AVENUE | SHEET 40 OF 43 | | |
| SECURITY SYSTEM | CONSULTANT DRAWING NUMBER | | |
| CAMERA DETAILS | E-8 | | |