


LEGEND

- AREA LIGHTING LAMP AND POLE
- AREA LIGHTING POWER CABLE(S)
- 600/347 VOLT POWER CABLE
- DATA/COMMUNICATION CONDUIT

NOTE:

1. ALL BURIED CABLING SHALL BE INSTALLED IN HDPE CONDUIT BURIED 1000 mm BELOW FINISHED GRADE.
2. INSTALL COPPER CLAD GROUND ROD AT END OF LIGHTING CIRCUITS.
3. UNDERGROUND STREET LIGHT WIRING NOT SHOWN. WIRING SHALL BE #6AWG RWU-90 INSTALLED IN 53MM HDPE CONDUIT.
4. REFER TO HHW EWASTE LIGHTING PLAN E03 FOR AREA LIGHTING FIXTURE TYPE.
5. PULLBOX: CHRISTY B1730 H/20 LOADING.



UNDERGROUND CABLE INSTALLATION DETAIL
N.T.S.

METRIC

WHOLE NUMBERS INDICATE MILLIMETRES
DECIMALIZED NUMBERS INDICATE METRES

C:\projects\winnipeg\working_directory\active\4099_d024576A\138224-02-ELEC-CO009-10.dwg



B.M. ELEV.	DESIGNED BY	BLM
	DRAWN BY	SCK
	CHECKED BY	BLM
	APPROVED BY	ARR
	HOR. SCALE	AS NOTED
	VERTICAL	
1	ISSUED FOR TENDER	16/03/04 ARR
NO.	REVISIONS	DATE BY DATE

DILLON CONSULTING

RELEASED FOR CONSTRUCTION

ENGINEER'S SEAL

PROVINCE OF MANITOBA
B.L. MOORE
REGISTERED PROFESSIONAL ENGINEER

CONSULTANT PROJECT NUMBER
13-8224

THE CITY OF WINNIPEG
PUBLIC WORKS DEPARTMENT

4R WINNIPEG DEPOT
PACIFIC AVENUE

SITE PLAN LIGHTING LAYOUT

CITY DRAWING NUMBER
1-0851A-E0009-001

SHEET 41 OF 43

CONSULTANT DRAWING NUMBER
E-9