
MOTOR - EQUIPMENT SCHEDULE																			
	STARTER									POWER		POWER			DETAIL DWG.	REMARKS			
EQUIP. NO.	DESCRIPTION	EQUIP. LOAD	VOLT/Ø	SIZE	TYPE	MAN.	MAG.	S/S	PL	НОА	OVERCURREN DEVICE	LOCATION	PANEL	ССТ	FEEDER	CAPACITOR SIZE	DISCONNECT TYPE	WIRE DIAGRAM	
AC-01	AIR COMPRESSOR	15 HP	600/3								30A-3P	G-02	PP-WW	8,10,12	3C #10 TECK	30	A-3P CSA 3		PACKAGE UNIT
AC-02	AIR COMPRESSOR	60 HP	600/3	_	-	_	_				100A-3P	G-02	1B		3C #3 TECK	10	00A-3P CSA 3		DIRECT CONNECTION TO UNIT C/W PACKAGE VFD
D-1	DRYER	2.54 kW	600/3								15A-3P	G-02	PP-WW		3C #12 TECK	IN ⁻	TERNAL		DIRECT CONNECTION TO UNIT
D-2	DRYER	1/2 HP	120/1								15A-1P	G-20	LP-RM-B	CCT 2	2#12 AWG 21C	IN	TERNAL		DIRECT CONNECTION TO UNIT

—DEVICE LOCATED IN STARTER —DEVICE LOCATED IN FIELD ADJACENT TO EQUIPMENT.



DISTRIBUTION 1B MODIFICATIONS
N.T.S.

Certificate of Authorization Dillon Consulting Limited (MB) **No. 1789 Date**: APR. 10/15

LOCATION APPROVED B.M. ELEV. SCK UNDERGROUND STRUCTURES SCK DATE SUPV. U/G STRUCTURES COMMITTEE CHECKED BY APPROVED BY ISSUED FOR CONSTRUCTION APR.10/15 SCK MAR.20/15 SCK HOR. SCALE NOTED B CLIENT REVIEW 100% MAR.9/15 SCK A CLIENT REVIEW 99% DATE BY DATE 2015-02-20



DATE

ENGINEER'S SEAL B.L.
MOORE
April 10/15 So CONSULTANT PROJECT NO.

149749

Winnipeg THE CITY OF WINNIPEG TRANSIT DEPARTMENT CITY DRAWING NUMBER FORT ROUGE GARAGE COMPRESSED AIR P-XXXX- ----

SYSTEM UPGRADE CONSULTANT DRAWING NUMBER ELECTRICAL - SCHEDULES AND DETAILS E2