



604-2015 ADDENDUM 1

NORTH KILDONAN FEEDERMAIN – VALVE CHAMBERS AND CONNECTIONS

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: January 26, 2016
BY: Colin McKinnon
TELEPHONE NO. (204) 942-6391

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20150105

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

- Add: D15.4 The City intends to award by February 24, 2016.
- D15.4.1 If the actual date of award is later than the intended date, the dates specified for Commencement, Critical Stages, Substantial Performance, and Total Performance will be adjusted by the difference between the aforementioned intended and actual dates.
- Revise D16.1 The Contractor shall achieve Substantial Performance by June 17, 2016.

PART E – SPECIFICATIONS

- Revise: E16.2 The first phase of the project is near completion and subject to site surface restoration later this spring. The trenchless contractor has removed the rig mats used for the project.
- Revise: E16.3 The Contractor shall review Appendix C – Historical Drawings in conjunction with the outlined site access to assess the extent at which their methodology will impact the existing feedermain. Based on the determined construction impact the Contractor shall be responsible to take necessary precautions, subject to the approval of the Contract Administrator, to protect existing buried infrastructure while accessing the site during the course of construction.
- Revise: E16.7 (a) to read: Distribute vehicular loadings at any location where within 6m traveling along or crossing of the feedermain is required.
- Add: E19.11 The following are approved air vacuum and release valves for this project:
 - i) VENT-O-MAT RBX
 - ii) APCO CAV Model 151C
 - iii) Approved equal in accordance with B7
- Revise: E20.3(c) Polyethylene to Polyethylene joints: to be either thermal butt fusion joined to ASTM D2657 or by electrofusion coupler of the same DR rating to ASTM F1055. If electrofusion is used the manufacturer or manufacturer’s representative must witness and certify the installation.

- Add E20.4 (h) Primary system used for the interior / exterior finish of steel pipe shall be to AWWAC210 Fusion Bonded Epoxy. Other listed interior / exterior finishes shall be used as methods of field repair in the case of damage to the primary system onsite.
- Add: E20.10 (b) The following are approved flanged / compression sleeve couplings for this project:
- i) Robar 1908RSC
 - ii) Approved equal in accordance with B7
- Revise: E20.11 (b) to read: Exposed service - galvanized carbon steel bolts conforming to ASTM A307 Grade B with galvanized carbon steel nuts conforming to ASTM A307 Grade 2H, semi-finished hex head.
- Add: E20.12 (c) The following are approved joint restraints for this project:
- i) EBAA 2500 C905
 - ii) EBBA 2800 C905
 - iii) Or approved equal in accordance with B7.
- Add: E30 **EXPEDITED SHOP DRAWINGS**
- E30.1 Further to E8 in order to expedite Shop Drawings with critical timeliness, the Lowest Responsive Bidder, as outlined in **B15**, will be permitted, after receiving written approval from the Contract Administrator, to arrange for the preparation of Shop Drawings for the following items with critical timelines:
- (a) Butterfly Valves
 - (b) Steel Transition Section
 - (c) Ductile Iron Valve Chamber Pieces
 - (d) Couplers
 - (e) Dismantling Joint
- E30.2 If Award is made to the lowest responsive bidder, then as indicated in E8.14, no payment for the preparation of Shop Drawings will be made.
- E30.3 If no contract is awarded, then the City of Winnipeg will pay the requested Bidder up to a maximum of five hundred dollars (\$500.00) for each of the requested submissions noted above, for the preparation and delivery of Shop Drawings. Delivery of the Shop Drawings to the City and payment of the above amounts will constitute full and final consideration of each party to the other, and neither party will have any further liability to the other with respect to this Bid Opportunity.