



676-2015 ADDENDUM 1

REQUEST FOR PROPOSAL FOR PROFESSIONAL CONSULTING SERVICES FOR WEST END SEWAGE TREATMENT PLANT EFFLUENT MONITORING STATION

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
REQUEST FOR PROPOSAL**

ISSUED: September 10, 2015
BY: Lana Obach, P.Eng., M.A.Sc.
TELEPHONE NO. 204-986-8335

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE REQUEST FOR PROPOSAL AND
SHALL FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: Ar20150806

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Request for Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Proposal may render your Proposal non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

Add: D7.4.13(j)

There is no expectation of emergency power generation for this building. Small battery back-up systems are expected in the design for components like the control system and emergency lighting.