



795-2015 ADDENDUM 1

CONSTRUCTION OF PARKS MAINTENANCE GARAGE IN SAGE CREEK AT 2050 WARDE AVENUE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: September 22, 2015
BY: Tracy Stople
TELEPHONE NO. 204 986-2221

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20150806

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

QUESTIONS AND ANSWERS

QUESTION #1: Do you have soils report available or do you know how deep the existing organic materials?

ANSWER: We do not have soils information for this project.

QUESTION #2: Do you have specs for the skylight tubes and fuel shed?

ANSWER: The skylight tubes are 13" commercial series aluminum tubular skylights with 2-24" tubes. The fuel shed is to be provided by "others".

CLARIFICATION

The intent of this project is to construct the garage this year and to complete the landscaping next spring.