

**Part 1            General**

**1.1                REFERENCES**

- .1 American National Standards Institute (ANSI)
  - .1 ANSI/NFPA 10-2010, Portable Fire Extinguishers.
- .2 Underwriters' Laboratories of Canada (ULC)
  - .1 CAN/ULC-S508-2002 (R2007), Rating and Fire Testing of Fire Extinguishers and Class "D" Extinguishing Media.

**1.2                SHOP DRAWINGS AND PRODUCT DATA**

- .1 Submit shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures.

**1.3                CLOSEOUT SUBMITTALS**

- .1 Provide maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

**Part 2            Products**

**2.1                MULTI-PURPOSE DRY CHEMICAL EXTINGUISHERS**

- .1 Stored pressure rechargeable type with hose and shut-off nozzle, ULC labelled for A, B and C class protection.
- .2 Size: 4.5 kg.

**2.2                EXTINGUISHER BRACKETS**

- .1 Type recommended by extinguisher manufacturer.

**2.3                IDENTIFICATION**

- .1 Identify extinguishers in accordance with recommendations of CAN/ULC-S508.
- .2 Supply and install an identification lamacoid adjacent to each fire extinguisher.
- .3 Attach tag or label to extinguishers, indicating month and year of installation. Provide space for service dates.

**Part 3            Execution**

**3.1                INSTALLATION**

- .1 Install or mount extinguishers in cabinets or on brackets as indicated.

- .2 Attach lamacoids with screws.

**END OF SECTION**