



85-2015 ADDENDUM 1

WATER TREATMENT RESEARCH AND PROCESS OPTIMIZATION FACILITY – MECHANICAL AND ELECTRICAL WORK

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: March 11, 2015
BY: Scott Begg
TELEPHONE NO. (204) 488-2214

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20131129

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

SECTION 23 34 00.01 – Fan Schedule

Revise: EF-X606, EF-X607, EF-X608, EF-X609 with:

TYPE: Centrifugal
MANUFACTURER AND MODEL NO.: Plastec Series 15-2
MIN DIA (mm): 150
ELECTRICAL DATA: 0.37 kW, 3450 rpm, 1 Phase, 115V