



865-2015 ADDENDUM #1

GYM LIGHTING UPGRADE – 999 SARGENT AVENUE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: JUNE 2, 2016
BY: KATHY ROBERTS
TELEPHONE NO. 204 470-7380

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20150806

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

- Add: D2.6 Due to the low wattage of the new LED fixtures, the new fixtures will not need to have time delay.
- Add: D2.7 Firestopping will be required to seal any openings made by the Contractor in the gym wall.