



865-2015 ADDENDUM #2

GYM LIGHTING UPGRADE – 999 SARGENT AVENUE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: JUNE 9, 2016
BY: KATHY ROBERTS
TELEPHONE NO. 204 470-7380

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20150806

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

- Revise: D2.2(f) to read: Disconnect and remove existing lighting control panel in gym ceiling. Supply and install new recessed control panel next to electrical panels. Relocate all associated wiring from ceiling. New dimming controls will be located in this panel. Include trim around panel, where it meets the corrugated metal wall.
- Add: D2.2(g) Remove redundant conduit and wiring that was part of the existing lighting system.