


FIRE DAMPER SCHEDULE

TAG	DUCT SIZE	CONCRETE/CMU OPENING SIZE	LOCATION	DAMPER TYPE	MODEL	MATERIAL
FD-R640-1	250 DIA	325x350	ELECTRICAL ROOM	CR	130	GS61
FD-R640-2	200X150	225X225	CORRIDOR	B	120	GS61
FD-R653-1	150 DIA	225x250	JANITOR'S ROOM	CR	130	GS61
FD-R620-1	850x550	875x650	MECHANICAL ROOM	B	120	GS61
FD-R620-2	1100x400	1125x475	MECHANICAL ROOM	B	120	GS61
FD-R610-1	950X950	975x1100	MECHANICAL ROOM	B	120	GS61
FD-R610-2	750 DIA	825x900	GALLERY 8A	CR	130	GS61
FD-R610-3	500 DIA	575x625	GALLERY 5B	CR	130	GS61
FD-R611-1	500 DIA	575x625	GALLERY 5B	CR	130	GS61
FD-R612-1	900x900	925x1025	GALLERY 8A	B	120	GS61

NOTE: DAMPER MANUFACTURER, NAILOR HART

OVERALL ROOF PLAN
1:100

- NOTES:
- REFER TO ARCHITECTURAL DETAILS FOR GAS PIPE SUPPORT ON ON ROOF AND GAS PIPE THROUGH ROOF.
 - REFER TO ARCHITECTURAL DETAILS FOR VENT THROUGH ROOF
 - REFER TO ARCHITECTURAL DETAILS FOR GAS PIPE SUPPORT ON THE WALL



APEGM
Certificate of Authorization
CH2M HILL Canada Ltd.
No. 1441

		DESIGNED BY: D. LE	CHECKED BY: T. TRAN		
DRAWN BY: A. BERSHTEIN	APPROVED BY: H.T. FREIHAMMER	SCALE: 1:100	ISSUED FOR CONSTRUCTION BY: T. TURZAK	DATE: 2016/02/18	DATE: 2016/02/18
01 ISSUED FOR ADD. 4 - B.O. 899-2015 03/2016 A.B. J.C.		00 ISSUED FOR ADD. 1 - B.O. 899-2015 02/2016 A.B. J.C.		CONSULTANT NO.: 474248	
NO. REVISIONS		DATE DESIGN CHECK		CITY DRAWING NUMBER 1-0102-MGAD-R611	

SHEET REV. SIZE
001 01 A1