

- SHALL BE PERMITTED WHEN A DUCT MOUNTED DAMPER

./	٩.	C.	•

- 8. THE USE OF FLEXIBLE DUCT WORK SHALL BE LIMITED TO ONLY CONNECTIONS BETWEEN DUCT BRANCHES AND DIFFUSERS AND SHALL HAVE A MAXIMUM LENGTH OF 5 FT WHEN FULLY STRETCHED AND SUPPORTED BY A DURABLE
- DIFFUSERS SHALL BE COORDINATED ON SITE WITH THE FINAL CEILING LAYOUT AND THE EQUIPMENT OF OTHER TRADES. SUPPLY DUCTS TO FORM CUSHION HEADS AFTER
- 11. A RETURN OR RELIEF GRILLE SHALL BE INSTALLED IN EACH
- HAVING A FLAME SPREAD RATING ABOVE 25 OR A SMOKE ACCORDANCE WITH ASTM E84 (UL 723) SHALL NOT BE USED
- TO THE REQUIREMENTS OF THE LATEST EDITION OF ASHRAE 90.1 AND TO THE REQUIREMENTS OF THE MANITOBA ENERGY CODE FOR BUILDINGS. ALL DUCT PENETRATION AND ALL DUCT WORK CONTAINING
- 14. ALL SIZES OF DUCTWORK INDICATED ON THE DRAWINGS DENOTE THE INTERNAL OPEN DUCT DIMENSIONS. ALLOWANCES SHALL BE MADE FOR ANY INTERNAL INSULATION INDICATED ON THE DRAWINGS OR REQUIRED
- 15. ALL CUTTING AND/OR PATCHING OF ROOFS, FLOORS, AND EXTERIOR WALLS SHALL BE BY THE CONTRACTOR

H.V.A.C. LEGE	ND				
		DIFFUSER			
		GRILLE/REGISTER/DIFFUSER			
		RETURN AIR GRILLE			
		EXHAUST AIR GRILLE			
		SUPPLY DUCT RISE / DROP			
		RETURN DUCT RISE / DROP			
		EXHAUST DUCT RISE / DROP			
	2	ROUND DUCT RISE / DROP			
		THERMAL INSULATION			
		ACOUSTIC INSULATION			
		FLEX CONNECTOR			
		NEW DUCT			
		H.V.A.C. CONTROL			
<u> </u>		THERMOSTAT C/W GUARD			
	^	GUARD			
	\$	BALANCING DAMPER			
		DAMPER BACK DRAFT / MOTORIZED / FIRE / SMOKE			
TYPE SIZE FLOW		DIFFUSER TAG			
TAG CAP.		ELECTRIC HEAT TAG			
		DRAWING NOTE			
EQP #		EQUIPMENT TAG			
1 2017.02.21 ISUED FOR CONSTRUCTION No. DATE REVISION / ISSUANCE Sel					
<section-header><section-header><text><text><text><section-header><section-header><section-header><text></text></section-header></section-header></section-header></text></text></text></section-header></section-header>					
MAIN FLOOR H.V.A.C. Project No. 1487					
		VI-ZU1			