

# 1058-2016 ADDENDUM No. 1

## REPLACEMENT OF DOMESTIC HOT WATER SYSTEM AT PAN AM POOL – 25 POSEIDON BAY

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: 16 December 2016  
BY: P. Silva, P.Eng.  
TELEPHONE NO. 204 896-1209

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20160708

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.**

---

### **PART E – SPECIFICATIONS**

#### **DIVISION 01:**

##### **Section 01 00 10 - General Requirements**

- Add: 11.4 The following Work shall take place after normal operating hours of the Pan AM Pool:
- All Work outside of the boiler room.
  - Any Work inside the boiler room that would be disruptive to the staff or facility users.
  - All service shutdowns shall be limited to after hour shifts not exceeding 8 hours. All services shall be restored prior to opening of the facility next day and shall be co-ordinated with the Contract Administrator.

#### **DIVISION 22:**

##### **Section 22 30 05 - Domestic Water Heaters**

- Add: 2.1.17 The following product(s) have been approved as equal: (Domestic Hot Water Boilers, DWB-1 & DWB-2) – Camus Dynaforce 1400.
- Add: 2.3.3 The following product(s) have been approved as equal: (Condensate Neutralizer) - Axiom.
- Add: 2.3.4 Boiler Condensate Piping: Rigid polyvinyl chloride (PVC), Schedule 40, to CSA B137.3.

#### **DIVISION 23:**

##### **Section 23 05 19.01 - Thermometers and Pressure Gauges**

- Add: 2.2.2 The following product(s) have been approved as equal: (Direct Reading Thermometers) - H.O. Terrice.
- Add: 2.3.3 The following product(s) have been approved as equal: (Thermometer Wells) - H.O. Terrice.

Add: 2.4.3 The following product(s) have been approved as equal: (Pressure Gauges) - H.O. Trerice.

**Section 23 21 13.02 - Hydronic Piping Systems**

Add: 2.4.4.3 The following product(s) have been approved as equal: (Balancing Valves) - Bell & Gossett.

**Section 23 21 14 - Hydronic Specialties**

Add: 2.1.3 The following product(s) have been approved as equal: (Air Vents) – Bell & Gosset.

Add: 2.3.3 The following product(s) have been approved as equal: (Chemical Pot Feeder) – Axiom.

Add: 2.4.3 The following product(s) have been approved as equal: (Flow Indicator/Sight Glass) – Axiom.

**Section 23 37 13 - Diffusers, Registers and Grilles**

Add: 2.2.2 The following product(s) have been approved as equal: (Fire Rated Door Grille) – Nailor.

**DRAWINGS**

Replace: 1058-2016\_Drawing\_S01-R0 with 1058-2016\_Addendum\_1\_Drawing\_S01-R1

Replace: 1058-2016\_Drawing\_S04-R0 with 1058-2016\_Addendum\_1\_Drawing\_S04-R1

Replace: 1058-2016\_Drawing\_M01-R0 with 1058-2016\_Addendum\_1\_Drawing\_M01-R1

Replace: 1058-2016\_Drawing\_M02-R0 with 1058-2016\_Addendum\_1\_Drawing\_M02-R1

Replace: 1058-2016\_Drawing\_M03-R0 with 1058-2016\_Addendum\_1\_Drawing\_M03-R1

Replace: 1058-2016\_Drawing\_M06-R0 with 1058-2016\_Addendum\_1\_Drawing\_M06-R1

Replace: 1058-2016\_Drawing\_M07-R0 with 1058-2016\_Addendum\_1\_Drawing\_M07-R1

Replace: 1058-2016\_Drawing\_E05-R0 with 1058-2016\_Addendum\_1\_Drawing\_E05-R1