

APPENDIX B (R2) – WATERMAIN RENEWAL LOCATIONS

TABLE A

STREET NAME	LOCATION DETAILS	DIAM. (mm)	LENGTH (M)
PRINCESS ST	HIGGINS AV TO JAMES AV	300	521
ALEXANDER AV	PRINCESS ST TO KING ST	300	83
JAMES AV	PRINCESS ST TO KING ST	300	156
HENRY AV	PRINCESS ST TO KING ST	200	81
KING ST	JAMES AV TO WILLIAM AV	250	139
WATERMAIN ABANDONMENT- PRINCESS ST	VARIOUS	varies	varies
TOTAL BUDGET		\$1,905,461	

TABLE B

PLEASE NOTE: The locations and quantities of the abandonments detailed in Appendix B are based upon a preliminary review by Water and Waste staff. The abandonment of hydrants, valves and interconnections should not be limited to these quantities/locations and could vary once a more detailed review is performed by the Consultant.

LOCATION	ACTION REQUIRED
Princess Street @ Higgins Avenue	<ul style="list-style-type: none"> • Cut and Plug 300 CI WM
Princess Street @ Henry Avenue	<ul style="list-style-type: none"> • Abandon 250mm Valve. • Abandon Hydrant and Valve. • Remove interconnect between two mains at King Street (cut out 200mm Tee and pipe through
Princess Street @ Logan Avenue	<ul style="list-style-type: none"> • Abandon Hydrant and Valve. • Abandon 300mm Valve

LOCATION	ACTION REQUIRED
Princess Street @ Alexander Avenue	<ul style="list-style-type: none">• Connect 250 CI East of Princess to 300 CI West of Princess
Princess Street @ Pacific Avenue	<ul style="list-style-type: none">• Abandon 300mm Valve.
Princess Street @ Rupert Avenue	<ul style="list-style-type: none">• Abandon Hydrant and Valve.
Princess Street @ James Avenue	<ul style="list-style-type: none">• Abandon 2- 300mm Valve. Connect 250 CI WM into 300 CI WM on South side of James Avenue
Princess Street @ South of Elgin Avenue	<ul style="list-style-type: none">• Abandon 300mm Valve
Princess Street @ William Avenue	<ul style="list-style-type: none">• Abandon 300mm Valve