



186-2016 ADDENDUM 02

NORTH END WATER POLLUTION CONTROL CENTRE (NEWPCC) DEWATERING CENTRIFUGE OVERHAUL SERVICES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: April 11, 2016
BY: Ashley Dent
TELEPHONE NO. 204 896-1209

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20150806

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Bid may render your Bid non-responsive.

PART A – PROPOSAL SUBMISSION

Replace: Form B: Prices with Form B (R1): Prices.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, April 22, 2016.

PART C – GENERAL CONDITIONS

Clarification of C16.1: Liability insurance shall be provided in accordance with the City of Winnipeg General Conditions as outlined Part C16 of the RFP.

PART E – SPECIFICATIONS

Replace: E1.1 Replace document:
MEC-001 - NEWPCC Dewatering Centrifuge Overhaul Services (Revision 0)
With document:
MEC-001 - NEWPCC Dewatering Centrifuge Overhaul Services (Revision 1)

Clarification of E1.1: With reference to 3.5.3. in the Technical Specification, the intent is to dynamically test the complete rotating assembly PRIOR to shipment so that any issues can be remedied prior to return shipment to the NEWPCC site.

Clarification of E1.1: With reference to 3.6.(1) in the Technical Specification, the rotating assembly can fit through the existing NEWPCC equipment lift well as a single assembly.