



218-2016 ADDENDUM 1

ARCHITECTURAL RESTORATION OF THE NORTH RBC CONVENTION CENTRE SKYWALK – 375 YORK AVENUE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: April 11, 2016
BY: Reg Spurrill
TELEPHONE NO. 204 942-0681

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20150806

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 pm Winnipeg time, April 14, 2016.

PART E – SPECIFICATIONS

Revise: Section 07 95 13 – 2.1 MANUFACTURERS, .1 Acceptable Products: Change 2.1.1.1.1 to read “Inpro JointMaster 807-A01-050/10 Expansion Joint System”.

Revise: Section 08 41 13 – 2.1 MANUFACTURERS, .1 Acceptable Products, .1 Interior Aluminum Entrance Framing (single glazed): Add the following Acceptable Products:

- .3 US Aluminum Series 450 Centre Glazed Aluminum Storefronts, 44 mm x 114 mm deep c/w US Aluminum Series 400 (medium style) aluminum doors c/w 81 mm top rail, 89 mm stiles, 260 mm mid rail, and 304 mm bottom rail.

Revise: Section 08 41 13 – 2.6 FINISHES, .1 Shop Finishing, .1 Exposed Aluminum Surfaces: Change 2.6.1.1.1 to read “Factory applied 3-coat Duranar or Permafluor paint system consisting of 70% fluoropolymer resin and polyvinylidene fluoride (PVDF) in accordance with AAMA 2605, colour: custom white”.

Add: Section 08 71 00 – 2.1 MANUFACTURERS, .1 Door Hardware: Add Finish Hardware included in this Addendum.

Revise: Section 08 71 13 – 2.3 CONCEALED AUTOMATIC SWING DOOR OPERATOR SYSTEM: In sentence 2.3.1 and 2.3.1.1, delete all references to “Pivots”. No pivots will be required by the door operator system.

Revise: Section 09 29 00 – 2.1 MANUFACTURERS, .1.3 Stainless Steel Corner Guards: Change 2.1.1.3.1 to read “Specialloy SCGB-3 Panelled Wall Corner Guard #3 (full height and as indicated)”.

Revise: Section 09 29 00 – 2.1 MANUFACTURERS, .1 Acceptable Products: Add the following Acceptable Products:

- .4 Stainless Steel Base: Specialloy custom stainless steel base as detailed.

Revise: Section 09 54 23 – 2.2 COMPONENTS, .1 Linear Panels: Change 2.2.1.2 to read “Aluminum: roll-formed aluminum sheet 0.6 mm (24 ga.) to ASTM B209, factory-finished in baked enamel paint finish, colour: white (to be local shop spray painted by others to match existing linear panels)”.

Revise: Section 09 90 00 – 1.1 SUMMARY: Add the following:

- .5 Work under this Contract includes surface preparation, priming and local shop spray painting of Linear Metal Ceiling Panels specified in Section 09 54 23 to match existing linear panels (2 colours).

DRAWINGS

Replace: 218-2016 _Drawing _A0–R3 with 218-2016 _Addendum _1-Drawing A0-R4

Replace: 218-2016 _Drawing _A1–R3 with 218-2016 _Addendum _1-Drawing A1-R4

Replace: 218-2016 _Drawing _A2–R3 with 218-2016 _Addendum _1-Drawing A2-R4

Replace: 218-2016 _Drawing _A3–R3 with 218-2016 _Addendum _1-Drawing A3-R4

Replace: 218-2016 _Drawing _A4–R3 with 218-2016 _Addendum _1-Drawing A4-R4

Replace: 218-2016 _Drawing _A5–R3 with 218-2016 _Addendum _1-Drawing A5-R4

Replace: 218-2016 _Drawing _M1–R3 with 218-2016 _Addendum _1-Drawing M1-R4

Replace: 218-2016 _Drawing _E1–R3 with 218-2016 _Addendum _1-Drawing E1-R4

Replace: 218-2016 _Drawing _E2–R3 with 218-2016 _Addendum _1-Drawing E2-R4