

NOTES:

REMOVE EXISTING RAINWATER LEADER. PATCH HOLES IN CEILING AND FLOOR WITH MORTAR AS PER SECTION 030510 OF THE SPECIFICATIONS.

B REMOVE EXISTING FAN, STAND, AND SUPPLY DUCTWORK ON MAIN FLOOR LEVEL. SUPPLY DUCTWORK IN FLOOD PUMP ROOM TO REMAIN AND TO BE REUSED.

© REMOVE RECTANGULAR SUPPLY DUCTWORK ON MAIN FLOOR AND IN THE COMMINUTOR MOTOR ROOM AND COMMINUTOR CHAMBER.

D REMOVE INTAKE DUCTWORK. INTAKE SCREEN IN BUILDING EAVE TO REMAIN.

E REMOVE EXISTING UNIT HEATERS.

F EXISTING DUCTWORK TO REMAIN.

G FILL IN EXISTING PENETRATIONS. MATCH EXISTING BRICKWORK. MORTAR AS PER SECTION 030510 OF THE SPECIFICATIONS.

H REMOVE LEVEL INDICATOR INCLUDING CABLE AND FLOAT IN WET WELL BELOW FLOOD PUMP MOTOR ROOM. FILL IN FLOOR PENETRATION AS PER SECTION 030510 OF THE SPECIFICATIONS.

				SNC+LAVALIN	SNC-LAVALIN INC. 148 Nature Park Way Winnipeg, MB, Canada R3P 0X7 204-786-8080	ORIGINAL DRAWING SEALED BY: T. SCHICK SNC-LAVALIN MEMBER #21892	THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT			
				DESIGNED BY: T. SCHICK	CHECKED BY: S. NORSWORTHY		COCKBURN FLOOD AND WASTEWATER PUMPING STATION 2016 UPGRADES MECHANICAL FLOOR PLAN MAIN FLOOR DEMOLITION			
				DRAWN BY: D. BOURGEOIS	APPROVED BY: I. PARKINSON					
				SCALE: 1:40	ISSUED FOR CONSTRUCTION BY: K. ZUREK					
		2040/05/00		DATE: 2015/11/17	DATE: 2016/05/06		CITY DRAWING NUMBER	SHEET	REV. SIZ	
00 NO.	ISSUED FOR TENDER, BID OP. 331–2016 REVISIONS	2016/05/06 DATE	TS DESIGN C	CONSULTANT NO.:			1-0127A-M0001	001	00 A	

1-0127A-M0001-001-00.dwg