



337-2016 ADDENDUM 1

2016 WATERMAIN RENEWALS – CONTRACT NO. 6

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: May 3, 2016
BY: Rob Sherlock
TELEPHONE NO. 204 489-5900

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20150806

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

- Add: **E14.** **Existing Cathodic Protection**
- Add: E14.1 Existing watermains on Woodlawn Street, Belvidere Street and Acheson Drive are cathodically protected. This includes anode banks, wires and cathodic protection test stations. Any damage to this system on existing watermains that are to remain in operation must be reported to the Water and Waste Department immediately. Furthermore, all costs, materials and labour associated with the restoration of this system, if damaged, will be the responsibility of the Contractor.
- Add: E14.2 Existing monitoring station MBM004 on Woodlawn Street to be abandoned. Station to be abandoned by cutting the wire under the station and backfilling the excavation. Existing monitoring station MBM004 is located approximately 4.3m N of S lot line #215 Woodlawn Street.
- Add: E14.3 Existing anode BM0420 on Woodlawn to remain. Existing anode BM0420 is located approximately 0.1m NSL Lodge Avenue.
- Add: E14.4 Existing monitoring station MBN047 on Acheson Drive to remain. Existing monitoring station MBN047 is located approximately 17.0m WWL Arthur Creek Drive.
- Add: E14.5 Measurement and payment for abandoning of existing monitoring stations will be included with the watermain work.