



1. VERIFY LOCATIONS OF UTILITIES AND PROTECT ALL ELECTRICAL EQUIPMENT AGAINST DAMAGE DURING CONSTRUCTION.
2. COORDINATE POLE FOOTINGS AND POWER LOCATIONS WITH LANDSCAPE DRAWINGS.
3. CONDUIT IS SHOWN FOR CONFIGURATION AND CLARITY. CONTRACTOR SHALL DETERMINE ROUTING OF CONDUITS TO SUIT SITE CONDITIONS.
4. WHERE CONDUITS ARE ROUTED UNDER ROADWAYS, COORDINATE DEPTH OF BURIAL WITH CITY OF WINNIPEG REQUIREMENTS.

1. PROVIDE NEW POST-TOP LUMINAIRES AS SPECIFIED C/W POLES TO MATCH EXISTING. REFER TO LANDSCAPE DRAWINGS FOR POLE BASE DETAIL.
2. NEW PANEL D SHALL BE FREE-STANDING WEATHERPROOF PANELBOARD C/W EXTERIOR MOUNTED REMOTE METERING CABINET. REFER TO DETAIL 3/E1.0.
3. LUMINAIRE SHALL BE MOUNTED TO EXISTING STEEL PLATE ON MUSEUM WALL. CONNECT TO EXISTING AC-90 AT EXTERIOR OF BUILDING AND ENSURE WIRING IS CONNECTED TO EXISTING MUSEUM EXTERIOR LIGHTING CIRCUIT.

1.47

	5.00
--	------

