


KEY NOTES

- 1 LOCATE DISCONNECT ON FREE SPACE ON COLUMN.
- 2 PROVIDE 40A/3P BREAKER FOR NEW PUMP P-1B IN EXISTING SQUARE D NQ PANEL 'R' IN ELECTRICAL DISTRIBUTION ROOM LOCATED ON BASEMENT LEVEL.



O 16-04-19 Issued for Construction
 No. DATE ISSUANCE
 Seal



APEGM
 Certificate of Authorization
 Epp Siepmann Engineering Inc.
 No. 4035

es|e epp siepman engineering
 400 - 136 Market Avenue
 Winnipeg, MB R3B 0P4
 T 204 453 1080

Client

Project
 PAN AM POOL VALVE AND SERVICES REPLACEMENTS
 25 POSEIDON BAY

Sheet Title

BASEMENT ELECTRICAL PLANS

1 : 100

Bid
 Opportunity
 383-2016

E1.2

1 BASEMENT - POWER
 E1.2 SCALE: 1 : 100