



421-2016 ADDENDUM 1

DEMOLITON OF TWO BOILERS AT PAN AM POOL-25 POSEIDON BAY

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: May 10, 2016
BY: Terry D. Karan, C.E.T.
TELEPHONE NO. 204 986-7146

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20150806

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

- Revise: D2.2(d) to read: remove existing breaching up to boiler B-3, owner will cap breaching at boiler B-3 prior to boiler demolition;
- Revise: D2.2(f) to read: existing combustion air to remain as is;
- Revise: D2.2(m) to read: electrical removal to be done by the City prior to boiler demolition;