



580-2016 ADDENDUM #3

ROOF REPLACEMENT – SARGENT PARK ARENA – 1111 WALL STREET

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: JULY 25, 2016
BY: KARL BAUCH
TELEPHONE NO. 204 794-4905

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, July 28, 2016.

PART E – SPECIFICATIONS

Revise: E6.13 to read: EAVE AND VALLEY PROTECTION

- (a) Eave and Valley Protection shall be applied to the entire roof area identified in the Work.
- (b) Supply and install IKO Goldshield Ice & Water Protector as manufactured by IKO Industries Ltd., Palisade SA-HT by SDP Advanced Polymer Products Inc., Lastobond Pro Grip by Resisto, or approved equal in accordance with B7.
- (c) Supply and install Rhinorooft U20, or approved equal in accordance with B7, over top of the Ice & Water Protector noted in E6.13(b).