



## 582-2016 ADDENDUM #2

### LIGHTING UPGRADE – ERIC COY ARENA – 535 OAKDALE DRIVE

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: JULY 13, 2016  
BY: KATHY ROBERTS  
TELEPHONE NO. 204 470-7380

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20160708

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART D – SUPPLEMENTAL CONDITIONS**

Revise: D2.2(h) to read: Disconnect, remove and dispose of existing wall-mounted ballasts and splitter boxes associated with existing mercury fixtures over ice surface. Supply and install a junction box in each location to terminate wiring (**total of 5 locations**).