



584-2016 ADDENDUM 1

SANDBLASTING, CONCRETE SUBSTRATE PREPARATION AND REPAINTING OF INTERIOR POOL TANK – ELDON ROSS INDOOR POOL

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: June 27, 2016
BY: Lou Chubenko
TELEPHONE NO. 204 986-2727

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20150806

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

- Add: D2.2(f) Eldon Ross Indoor Pool will be closed to the public and staff for pool maintenance shutdown period from September 6, 2016 to October 1, 2016.
- Revise: D14.1 to read: The Contractor shall achieve Total Performance by September 16, 2016

PART E – SPECIFICATIONS

- Revise: E3.2 to read: Provide hoarding around perimeter of pool tank and above to provide enclosure with sheets, tarps and plastic for dust containment during sandblasting procedure.
- Add: E3.9 Contractor shall be responsible for removal and re-installation of existing pool access ladders and waterslides.
- Add: E4.7 Provide skim coat on the entire pool tank wall and floor surfaces with Sikadur 32 High-modulus epoxy coating as per manufacturer's written instructions.