



630-2016 ADDENDUM 2

EAST ELMWOOD COMMUNITY CENTRE STORAGE SHED & HOCKEY RINK ASPHALT SURFACING PROJECT – 490 KEENLEYSIDE STREET

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: August 22, 2016
BY: Rob Garvey
TELEPHONE NO. 204-488-3857

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: Section 32 37 00, 2.1 to read:

R-8460-RA Fixed bollard, 35.5” high x 4.5” wide, powdercoat finish as supplied by Reliance Foundry Co. Ltd., Unit 207, 6450 – 148 Street, Surrey, BC., phone 1-888-735-5680. www.reliance-foundry.com or approved equal in accordance with B7.

Revise: Section 32 37 00, 2.2 to read:

‘SCHEDULE OF FURNISHINGS

Item	Name	Quantity	Mounting
2.2 BOLLARDS	R-8460-RA, Fixed Bollard, Reliance Foundry Co. Ltd., or approved equal in accordance with B7.	2 Locations T.B.D.	Embedded

Add: 2.1.2 to Section 33 11 23:

2.1.2 Woven geo-textile fabric – supply in accordance with the current version of City of Winnipeg ‘Approved Products for Surface Works’.

Revise: Section 33 11 23, 3.1.1 to read:

3.1.1 Install geotextile fabric layer in accordance with City of Winnipeg Construction Standard CW 3130 – “Supply and Installation of Geotextile Fabrics” after subgrade is inspected and approved by Contract Administrator.”

DRAWINGS

Replace: 630-2016_Drawing_G101-R0 with 630-2016_Addendum_2 Drawing_G101-R1