



697-2016 ADDENDUM 1

2016 WATERMAIN RENEWALS – CONTRACT NO. 12

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: August 16, 2016
BY: Matthew Klowak, C.E.T.
TELEPHONE NO. (204) 986-3982

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20131129

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART A – BID SUBMISSION

Replace: 697-2016 Bid Submission with 697-2016 Bid Submission Addendum 1 . The following is a summary of changes incorporated in the replacement Bid Submission:

- Form B (R1): Update approximate quantity for item “B.2 a) – Hydrant Assembly SD-006” from 7 to 6.
- Form B (R1): Add item “B.3 a) - New Hydrant Assembly on Existing Watermain SD-006” and rename subsequent sections accordingly.
- Form B (R1): Add item “C.3 – Continuity Bonding” and rename subsequent sections accordingly.
- Form B (R1): Add item “C.4 a) i) – Fittings Bends (SD-004) 150mm – 22 1/2” and rename subsequent sections accordingly.
- Form B (R1): Add item “C.4 a) i) – Fittings Bends (SD-004) 150mm – 45” and rename subsequent sections accordingly.

Page numbering on some forms may be changed as a result.

PART E – SPECIFICATIONS

- Add: E11: Installation of Hydrant Assembly on Existing Watermain
- E11.1: Description
 - A) This Specification shall cover the installation of the hydrant assemblies on the existing Fifth Ave 150mm watermain
- E11.2: Construction Methods
 - A) Install the hydrant assembly on the existing watermain in accordance with CW 2110
 - B) Fill the excavations with Class 3 Backfill in accordance with CW 2030
 - C) Surface restorations shall be completed in accordance with CW 3230, CW 3510 and these specifications.
- E11.3: Method of Measurement and Payment
 - A) Installation of the hydrant assembly shall be measured on a unit basis and paid for at the Contract Unit Price for “New Hydrant Assembly on Existing Watermain” in Form B of the Bid Submission. All hydrant lead pipe in excess of 3 meters, backfill and surface restorations shall be included in the price for “New Hydrant Assembly on Existing Watermain (SD-007)”. The number of units to be paid for will be the total number of hydrant assemblies installed as identified on Drawing D-13479.