



## 721-2016 ADDENDUM 2

### LYNDALE DRIVE- MONCK AVENUE TO GAUVIN STREET, RIVERBANK STABILIZATION AND ASSOCIATED WORKS

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: October 11, 2016  
BY: Michael Van Helden, P. Eng.  
TELEPHONE NO. 204-975-9433

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20150806

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART E – SPECIFICATIONS**

Add: E16.2.1(h)

No riverbank grading shall be permitted prior to completion of rockfill column installation within 30 m upstream and downstream of the location to be graded, unless otherwise approved by the Contract Administrator.