



## 748-2016 ADDENDUM 1

### CONSTRUCTION OF 2700 TRUNK SEWER - COCKBURN & CALROSSIE SEWER RELIEF WORKS - CONTRACT 4

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: January 17, 2017  
BY: Ray Offman, P.Eng.  
TELEPHONE NO. 204 896-1209

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20160708

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART B – BIDDING PROCEDURES**

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, **January 31, 2017**

#### **APPENDICES**

Replace: 7.2.1 from Appendix B: Geotechnical Baseline Report (Final Rev 2) dated October 2016 with the following:

##### 7.2.1 Base Heave

The base of excavation and shoring should be designed to achieve a minimum factor of safety of **1.3** with respect to basal heave. Installation of groundwater monitoring well will be required at the location of each shaft to measure the piezometric elevation in the vicinity of the shaft during construction. Depending on the groundwater conditions at the time of construction, groundwater depressurization may be required to achieve the specified factor of safety against basal heave.