



767-2016 ADDENDUM 1

ROUTE 90 UNDERPASS PUMPING STATION – 2016 UPGRADES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: September 13, 2016
BY: Brian Cleven
TELEPHONE NO. (204) 786-8080

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: Clause B2.1 to read:

The Submission Deadline is 12:00 noon Winnipeg time, September 20, 2016.

PART D – SUPPLEMENTAL CONDITIONS

Delete: Clause D3

PART E – SPECIFICATIONS

Delete: Clause E17.2 (h).

Revise: Clause E17.3 to read:

The Contractor is responsible for evaluating the acceptability of all existing slice gate components and advise the Contract Administrator if any components are required to be replaced, beyond what is specified herein. Where additional material or labour are required, and are approved by the Contract Administrator, payment for these will be made through a Contract Change Order.

NMS Format Specifications

Section 23 05 13

Revise: Clause 1.3.1 to read:

Arrange with the local utility for the modification of a gas service to 34.5 kPa supply pressure. Pay applicable fees and assessments relative to modifying the service and establish clearly with the utility the work to be completed by this section.

Revise: Clause 2.3.1 to read:

Gas pressure reducing valve shall be a Fisher direct acting pressure regulator or approved equal in accordance with B7. Valve shall be suitable for indoor installations by the Authority Having Jurisdiction and capable of meeting the stationary gas engine fuel requirements at the rated load. Vent to a safe location.

Section 26 24 01

Delete: Clause 3.1.9.

Section 40 90 01

Revise: Clause 2.2.1 to read:

Supply and install enclosed two-position maintained emergency stop operator stations for the underpass pumps, P-U01 and P-U02.

Drawings:

Replace: 767-2016_Drawing_1-0310U-A0033-001-00 with 767-2016_Drawing_1-0310U-A0033-001-01
Replace: 767-2016_Drawing_1-0310U-A0034-001-00 with 767-2016_Drawing_1-0310U-A0034-001-01
Add: 767-2016_Drawing_1-0310U-A0036-001-00
Replace: 767-2016_Drawing_1-0310U-E0009-001-00 with 767-2016_Drawing_1-0310U-E0009-001-01
Replace: 767-2016_Drawing_1-0310U-E0010-001-00 with 767-2016_Drawing_1-0310U-E0010-001-01
Replace: 767-2016_Drawing_1-0310U-M0001-001-00 with 767-2016_Drawing_1-0310U-M0001-001-01

Reference Drawings:

Add: 767-2016_Drawing_U220-83-BS7
Add: 767-2016_Drawing_U220-83-P02
Add: 767-2016_Drawing_U220-83-P03
Add: 767-2016_Drawing_U220-83-P04

Photos:

Add: 767-2016_Influent_Sluice_Gate_Photos.pdf
Add: 767-2016_Wet_Well_Photos.pdf