



ROUTE 90 UNDERPASS PUMPING STATION – 2016 UPGRADES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: September 15, 2016
BY: Brian Cleven
TELEPHONE NO. (204) 786-8080

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: Clause B17.4 to read:

Further to B17.1(c), the Total Bid Price shall be the sum of the quantities multiplied by the unit prices for each item shown on Form B: Prices adjusted, if necessary, as follows:

- (a) if the lowest evaluated responsive Bid submitted by a responsible and qualified Bidder is within the budgetary provision for the Work, no adjustment will be made to the Total Bid Price; or
- (b) if the lowest evaluated responsive Bid submitted by a responsible and qualified Bidder exceeds the budgetary provision for the Work, the Total Bid Prices of all responsive Bids submitted by responsible and qualified Bidders will be adjusted by deducting item 6 in order to reduce the Total Bid Price.

Note to bidders: There is no change to Clause B17.4.1. This existing clause remains.

PART E – SPECIFICATIONS

Delete: Clause E17.2 (c).

Delete: Clause E17.2 (d).

Add: Clause E17.2 (j):
Using a thickness gauge, test the clearance between the wall thimble and the gate. Advise the Contract Administrator of unsatisfactory clearances.

Delete: Clause E17.5.

NMS Format Specifications

Section 23 05 13

Revise: Clause 1.3.1 to read:

Arrange with the local utility for the modification of a gas service to 34.5 kPa supply pressure. The costs from the Utility will be billed directly to the City, not the contractor. Establish clearly with the Utility the work to be completed by this section.

Drawings:

Replace: 767-2016_Addendum_1-Drawing_1-0310U-M0001-001-01 with
767-2016_Addendum_2-Drawing_1-0310U-M0001-001-02