

803-2016 ADDENDUM 1

BURROWS AVENUE PUMPING STATION UPGRADES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
REQUEST FOR PROPOSAL**

ISSUED: October 13, 2016
BY: Blair Moore
TELEPHONE NO. (204) 453 - 2301

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE REQUEST FOR PROPOSAL AND
SHALL FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: Ar20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Request for Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Proposal may render your Proposal non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, October 18, 2016.

PART E – SPECIFICATIONS

- Add: E4 Wet Well Clean Out
- Add: E4.1 The Contractor shall be responsible for the clean out of the Wet Well. Clean out shall be done by mechanical or manual methods and shall remove grit, tallow and other build-ups to the satisfaction of the Contract Administrator.
- Add: E4.2 The current level of accumulation in the Wet Well is not known. Higher levels of accumulation, above that anticipated by the Contractor will not be eligible for additional payments.
- Add: E4.3 The Contractor shall also ensure that all construction material and debris are removed from the well and chamber after completing the works and prior to start-up and commissioning of the new pumps.
- Add: E4.4 Provide evidence of the Wet Well clean out in the form of photographs, or other suitable means, acceptable to the Contract Administrator. Under no circumstances will the City pay for more than one clean out of the Wet Well. In the event that the areas are not clean at the end of the associated mechanical work, the Contractor is responsible for bearing the cost of re-cleaning.

NMS Format Specifications

Section 09 91 00 - Painting

- Add: 3.2.5 Existing paint may contain lead paint. Follow all required safety measures and disposal.

Section 26 05 20 – Wire and Box Connector (0-1000-V)

Replace with 803-2016_Addendum_1-NMS_Section_21 07 20

Section 26 05 20 – Drainage Waste and Vent Piping – Cast Iron and Copper

Replace with 803-2016_Addendum_1-NMS_Section_22 13 17

Section 26 05 20 – General Service Compressed Air Systems

Replace with 803-2016_Addendum_1-NMS_Section_22 15 00

Section 26 05 20 – Plumbing Specialties and Accessories

Replace with 803-2016_Addendum_1-NMS_Section_22 42 01

Section 23 33 15 – Dampers - Operating

Revise: 2.1.5 to read: Operators: equal to Belimo EF Series MFT or Alumavent.

Section 23 34 00 – HVAC Fans

Add: 2.2.2 Acceptable Manufacturers: Carnes, Greenheck, Soler & Palau.

Section 40 05 52 – Process Valves

Replace with 803-2016_Addendum_1-NMS_Section_40 05 52-R1

Section 43 21 13 – Centrifugal Pumps

Replace with 803-2016_Addendum_1-NMS_Section_43 21 13-R1

Section 43 21 14 – Temporary Wastewater Diversion

Revise: 2.3.1 to read: Provide portable diesel generator to provide backup power in the event of a utility failure. An automatic transfer switch shall be provided to switch between utility and generator power.

Revise: 3.1.4 to read: The Contractor shall provide a back-up diesel generator and automatic transfer switch on site for the continued pumping of wastewater in the event of a utility power failure. On-site fuel supply shall be a minimum of four (4) hours.

Photos

Add: Dry Wall Photos - 803-2016_Addendum_1_Pictures