



1081-2017 ADDENDUM 1

INTERIOR AND EXTERIOR ALTERATIONS AT PEMBINA TRAIL LIBRARY – 2724 PEMBINA HIGHWAY

ISSUED: January 18, 2018
BY: Greg Kucel
TELEPHONE NO. 204 986-3429

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

The following Substitutes have been approved:

Specified Product	Approved Equal Product
Kohler K-3609 Water Closets	Contrac Crista 4722BHV/4721BFV Water Closets
Kohler K-4652-A Toilet Seats	Bemis 1900 Toilet Seats
Non-Specified Toilet Supplies	Brasscraft KTSCS401DLX C Toilet Supplies
Kohler K-2035-1 Lavatories	Contrac Carmin 4610BHZ Lavatories
Kohler KP-10216-4-CP Faucets	Delta Commercial 22C331 Faucets and Trim
Non-Specified Strainers	Delta Commercial 33T260 Strainers
Non-Specified P-Traps	Delta Commercial 33T311 P-Traps
Non-Specified Lavatory Supplies	Brasscraft KTSCS400AX C Supplies
Kohler K-2609-SU-NA Lavatories	Franke Commercial OV1420U/5 Lavatories
Kohler K-16027-4 Faucets and Trim	Delta 534LF Faucets and Trim
Non-Specified Lavatory Supplies	Brasscraft KTSCS400AX C Supplies
Non-Specified P-Traps	Delta Commercial 33T360 P-Traps
Johnsonite Azorock VCT V-214 Ashes	Armstrong Standard Excelon VCT 51836 Shelter White
Horton Proslide Series 2003	Stanley DG2000 BiPart with recessed Access Control

- Add: E1.4(o) The City shall will move the books, bookshelves and remaining furniture within the facility to accommodate the interior alterations. The Contractor shall coordinate with Sub-Contractors and the City to find suitable areas to temporarily store the furniture and bookshelves on Site and minimize the moving required.
- Add: E1.4 (p) The new furniture shown on the drawings are for reference purposes only and not in contract
- Add: E1.5 (h) Reuse existing cabling where feasible. New cabling shall be Category 6. And be certified and tested to meet the minimum specifications in Telecommunications Industry Association TIA 568A.

Add: E1.5 (i) No installed cabling may be exposed to view outside of the wiring room.

Add: E1.5 (j) New electrical runs shall be installed in EMT conduit