



255-2017 ADDENDUM 1

SUPPLY, DELIVERY, AND INITIAL START-UP INSPECTION OF PUMPING EQUIPMENT FOR COMMUNITY ROW WASTEWATER PUMPING STATION

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: March 31 ,2017
BY: Brian Cleven, P. Eng.
TELEPHONE NO. (204) 786-8080

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

- Add: E5.2.1(a)(x) The pumps and motors shall be capable of being run in reverse rotation (via the variable frequency drive) in an attempt to de-rag the pump. When a de-ragging function is run, the pump will be run in reverse for approximately 5 to 10 seconds at approximately 20% to 40% speed. Approximately four to six attempts will be made, with a 20 to 30 second wait period between each attempt.
- Add: E5.2.4(d) The drive shaft guard shall extend to a height of at least 3.5 meters above the pump room floor.