



SYMBOL LEGEND	
(T)	THERMOSTAT
⊖	DUPLEX RECEPTACLE
⊖GFI	GFI DUPLEX RECEPTACLE
▬ _{BBH}	BASEBOARD HEATER
FE - 1	FIRE EXTINGUISHER

- DATA JACK
- GENERAL NOTES:**
- ALL OUTLETS INSIDE UNHEATED STORAGE SHED TO BE INSTALLED AT 1067mm A.F.F. UNLESS OTHERWISE NOTED
 - CONTRACTOR TO COORDINATE INSTALLATION OF ONE PHONE LINE INTO THE BUILDING – INCLUDING CONNECTION TO SERVICE PROVIDER NETWORK. LOCATE ONE (1) VOICE - DATA JACK IN ELECTRICAL ROOM. LOCATION TO BE DETERMINED BY CONTRACT ADMINISTRATOR.

ELECTRICAL POWER METER FOR SINGLE PHASE, 240V POWER.

ELECTRICAL TO SUPPLY & INSTALL METER & MAST TO SUIT MB HYDRO REQUIREMENTS. INCLUDE 750MM OF EXPOSED CABLE FOR POINT OF ATTACHMENT. CONTRACTOR TO COORDINATE OVERHEAD POWER CONNECTION TO MB HYDRO.

ELECTRICAL FIXTURE SCHEDULE		
LABEL	FIXTURE	SPECIFICATION
BBH	BASEBOARD HEATER	DIMPLEX LINEAR CONVECTOR 2500W, 240V - SINGLE PHASE #LC6025W31 (1500mm LONG) OR APPROVED EQUAL IN ACCORDANCE WITH B7.
HD	HAND DRYER	DIMPLEX SERIES ONE COMMERCIAL HAND DRYER, 120V, 1450W, WHITE. #20001WH. OR APPROVED EQUAL IN ACCORDANCE WITH B7.
T	THERMOSTAT	DIMPLEX LINE VOLTAGE THERMOSTAT 240V, 7-DAY PROGRAMMABLE. OR APPROVED EQUAL IN ACCORDANCE WITH B7.

NOTES:

1. ALL THERMOSTATS TO BE GANGED TO ONE THERMOSTAT.

1 ELECTRICAL POWER PLAN
1:50