



LIGHT FIXTURE SCHEDULE		
LABEL	FIXTURE	SPECIFICATION
TYPE A	INDUSTRIAL LED	PHILIPS VAPORLUME LED DW, #D-W-P-E-51LH-840-4-UNV. OR APPROVED EQUAL IN ACCORDANCE WITH B7.
TYPE B	LINEAR LED	LITHONIA BLT 1x4, 6000 NOMINAL LUMENS, CURVED LINEAR PRISMATIC LENS, 4000K CCT. # BLT4 60L ADP LP840. OR APPROVED EQUAL IN ACCORDANCE WITH B7.
TYPE C	LINEAR LED	PHILIPS FLUXSTREAM LED LINEAR, #LF-4-FR-31-35-U-LAG, C/W WIREGUARD #LF4WGW, AIRCRAFT CABLE KIT #SVCC60-UNV. OR APPROVED EQUAL IN ACCORDANCE WITH B7.
TYPE D	LINEAR LED	LITHONIA BLT 1x4, 4000 NOMINAL LUMENS, CURVED LINEAR PRISMATIC LENS W/ TRIM RINGS, 4000K CCT. # BLT4 40L ADPT LP840. OR APPROVED EQUAL IN ACCORDANCE WITH B7.
TYPE WS	EXTERIOR WALL MOUNT	PHILIPS WALL MOUNT LYTEPRO LED SCONCE, #LPW32-79DGY. OR APPROVED EQUAL IN ACCORDANCE WITH B7.
EL	EMERGENCY LIGHTING	EMERGI-LITE ESL SERIES EMERGENCY DUAL REMOTE HEADS W/ BATTERY BANK. #12ESL144/2; FACTORY WHITE. OR APPROVED EQUAL IN ACCORDANCE WITH B7.
\$	LIGHT SWITCH	SINGLE POLE COMMERCIAL DECORATOR PADDLE TYPE, C/W STAINLESS STEEL FACE PLATE. SWITCHES OF ONE MANUFACTURER TO BE USED THROUGHOUT PROJECT. OR APPROVED EQUAL IN ACCORDANCE WITH B7.

NOTES:

- COORDINATE INSTALLTION LOCATION OF CARBON MONOXIDE SENSOR WITH OTHER EQUIPMENT IN SHED.
- SUPPLY & INSTALL 12x12" PLASTIC BOX FOR BURGLAR ALARM WIRING. INSTALL BOX AT 1525mm AFF.
- SUPPLY & INSTALL MECHANICAL PROTECTION FOR ELECTRICAL INSTALLATION RUNNING IN VERTICAL DIRECTION WITH MAXIMUM SPACING OF 305mm. SUBMIT FOR CONTRACT ADMINISTRATOR'S REVIEW PRIOR TO ORDER.
- ELECTRICAL CONTRACTOR TO PROVIDE DISCONNECT SWITCHES FOR POWERED EQUIPMENT (MECHANICAL FANS, POWER DOOR OPERATOR, ETC.) TO SUIT CURRENT CODE REQUIREMENTS.

ELECTRICAL POWER DOOR OPERATOR; COORDINATE W/ ARCHITECTURAL

1 E - REFLECTED CEILING PLAN
1:50