



**CONCRETE SLAB ON GRADE SCHEDULE**

**S1**  
 150 CONCRETE SLAB ON MINIMUM 150 WELL  
 COMPACTED GRANULAR BASE, MINIMUM 300 WELL  
 COMPACTED GRANULAR SUB-BASE R/W 10M @ 400 O/C  
 EA. WAY TOP

**S2**  
 150 CONCRETE SLAB ON MINIMUM 150 WELL  
 COMPACTED GRANULAR BASE, MINIMUM 300 WELL  
 COMPACTED GRANULAR SUB-BASE R/W 15M L-  
 DOWELS @ 300 O/C TOP, 10M TRANSVERSE @ 400 O/C.  
 PROVIDE MINIMUM 150mm VOID FORM 1220 FROM  
 FACE OF GRADE BEAM AT FULL WIDTH OF MAN-DOOR  
 OPENING.

NOTE:  
 ADDITIONAL BACKFILL IS REQUIRED AROUND THE  
 SHED PERIMETER TO TIE INTO EXISTING ADJACENT  
 GRADES. REFER TO ARCHITECTURAL SITE PLAN FOR  
 EXTENT AND TYPE OF BACKFILL FOR FINISH GRADE  
 CONDITION.

**1 MAIN FLOOR FRAMING PLAN**

S201 1 : 75

