



264-2017 ADDENDUM #1

ROOF REPLACEMENT – STRATHCONA RECREATION CENTER – 233 MCKENZIE STREET

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: APRIL 3, 2017
BY: DAVID FIRTH
TELEPHONE NO. 204-451-4098

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: E1.2 to read: The following are applicable to the Work:

<u>Drawing No.</u>	<u>Drawing Name/Title</u>
R-1	ROOF PLAN
D-1	ROOF DETAIL

Revise: E9.3 to read: The existing perimeter lumber blocking is to remain in place.

Revise: E9.19 to read: The existing lumber blocker is to be raised with solid lumber blocking, to obtain a minimum height of 4" above the top of the new roofing.

DRAWINGS

Add: 264-2017 _Drawing_D-1