















ALL DRAWINGS AND SPECIFICATIONS ARE THE PROPERTY OF THE CONSULTANT. NO REPRODUCTIONS MAY BE MADE WITHOUT THE CONSENT OF THE CONSULTANT. THE CONTRACTOR SHALL VERIFY ALL DIMENSIONS, DATUMS AND LEVELS NOTED ON THE DRAWINGS WITH THE CONDITIONS ON SITE AND SHALL BE RESPONSIBLE FOR REPORTING ANY ERRORS OR OMISSIONS TO THE ENGINEER FOR ADJUSTMENTS. THIS DRAWING SHALL NOT BE SCALED.



- NOTES:
- SAWCUT DEPTH TO BE 1/4 OF THE TOTAL SLAB DEPTH. CONTRACTOR TO ENSURE THAT REBAR IS NOT CUT.
 - SAW CUTTING TO BE COMPLETED WITHIN 6 TO 18 HOURS AFTER PLACING CONCRETE.
 - AFTER THE SLAB HAS ACHIEVED FULL STRENGTH AND MOST ABOVE SLAB STRUCTURAL WORK HAS BEEN COMPLETED, ALL DEBRIS IS TO BE REMOVED FROM SAWCUTS AND FILL WITH MORTAR CONTAINING CEMENT SAND, AND LATEX BONDING AGENT (OR AS INSTRUCTED BY ARCHITECT, STRUCTURAL ENGINEER, AND CONTRACT ADMINISTRATOR), OR AS NOTED IN THE SPECIFICATIONS (CONFIRM WITH ARCHITECT, STRUCTURAL ENGINEER, AND CONTRACT ADMINISTRATOR). THE CONTRACTOR IS RESPONSIBLE THAT POST FILLING CAVITIES DO NOT REDUCE THE QUALITY OR DURABILITY OF FILLED JOINTS.
 - MAXIMUM SPACING OF SAWCUTS IN SLAB ON GRADE SHALL NOT EXCEED THE FOLLOWING UN:
 - 100 SLAB - 3600 ON CENTRE
 - 130 SLAB - 4500 ON CENTRE
 - 150 SLAB - 6100 ON CENTRE
 - COORDINATE EXACT LOCATION OF SAWCUTS IN SLAB ON GRADE WITH ARCHITECTURAL FLOOR FINISHES.



Revisions

Date	Revision	ISSUED FOR CONSTRUCTION
17.05.30	1	ISSUED FOR CONSTRUCTION

Prime Consultant:

KNH SAWATZKY & ASSOCIATES
STRUCTURAL ENGINEERING CONSULTANTS

100 - 128 James Avenue
Winnipeg, Manitoba, Canada
R3B 0H6
NORTH@NSKY.COM
Tel: 204.959.7979
204.943.6767

Northern Sky Architecture Inc.

100 - 128 James Avenue
Winnipeg, Manitoba, Canada
R3B 0H6
NORTH@NSKY.COM
Tel: 204.959.7979
204.943.6767

Stamp

PROVINCE OF MANITOBA
May 30, 2017
M. SAATZKY
30986
REGISTERED PROFESSIONAL ENGINEER

Stamp - STRUCTURAL ONLY
- CONTACT ENGINEER WHEN INSPECTIONS ARE REQUIRED

Project
La Barriere Park Washroom Replacement
La Barriere Park, Manitoba

Certificate of Authorization
KNH Sawatzky & Associates Ltd.
No. 1193 Date: May 30, 2017

drawing title
TYPICAL SECTIONS AND DETAILS

scale	as noted	designed by	js/mi
date	May 2017	drawn by	js
project no.	337-2017	approved by	mi
reference no.	16.235	sheet	S3.1 REV.