

PLC RACK – LAYOUT

| | | | | | | | |
|--|---------------------------|---|---|---|---|--|---------------------------|
| BMX CPS 2010 POWER SUPPLY 24 VDC | BMX P58 1020 PROCESSOR | BMX DAI 1604 120 VAC INPUT 16 CHANNEL | BMX DRA 1605 120 VAC RELAY OUTPUT 16 CHANNEL | BMX AMI 0410 ANALOG INPUT 4 CHANNEL FULLY ISOLATED | BMX AMI 0410 ANALOG INPUT 4 CHANNEL FULLY ISOLATED | BMX AMO 0410 ANALOG OUTPUT 4 CHANNEL FULLY ISOLATED | BMX MEM 010 SLOT COVER |
| SLOT 0 | SLOT 1 | SLOT 2 | SLOT 3 | SLOT 4 | SLOT 5 | SLOT 6 | SLOT 7 |

| | | | | | |
|--------------------|--|---|-------------------|--|---|
| B.M. ELEV. | DESIGNED BY BLM DRAWN BY SCK CHECKED BY - APPROVED BY - |  | ENGINEER'S SEAL |  | CITY DRAWING NUMBER 1-0101M-E0060-001 SHEET 9 OF 21 |
| 0 NO. REVISIONS | 17/04/13 DATE | BLM BY | VERTICAL SCALE | RELEASED FOR CONSTRUCTION | CONSULTANT PROJECT NO. 163526 |
| | | | | NORTH END SEWAGE TREATMENT PLANT NEWPCC MAIN BUILDING - HVAC REPLACEMENT PLC RACK - LAYOUT | E-03 |