

PLAN
SCALE 1:25

NEW DISTRIBUTION PANEL 'PNL-L010'								
CCT NO	DESCRIPTION	LOAD	TRIP AMPS	N	TRIP AMPS	LOAD	DESCRIPTION	CCT NO
01	PANEL RECEPT.		15A	N AB	15A		ALARM PANEL	02
03	MAIN FLOOR LIGHTS		15A		15A		RTU CONTROL PANEL	04
05	BULKFILL CONTROL PANEL		15A		15A		SITE LIGHTING	06
07	HEATER		15A		15A		UPS	08
09			2P		15A		SPARE	10
11	SPARE		15A		15A		SPARE	12
13	RECEPT. (GFCI)		15A				SPACE	14
15	SPARE		15A				SPACE	16
17	SPARE		15A				SPACE	18
19							SPACE	20
21	TVSS						SPACE	22
23							SPACE	24

VOLTAGE: 120/240V PHASE: 1 WIRE: 3 BREAKER I.C.: 10 kAIC
 MAIN BREAKER: 100A MAINS: 100A FEEDER: OVERHEAD FROM UTILITY
 MOUNTING: SURFACE LOCATION: -
 FED FROM: UTILITY SERVICE
 NOTES: SERVICE ENTRANCE RATED
 -
 -
 -

FILENAME: 175009-11-SHT-DES-E06.DWG. PLOTTED BY: KOWALSKI, STANLEY
 PLOT DATE: 2017-11-24 @ 9:04:27 AM PLOT SCALE: 1:1.0008 PLOT STYLE: FULL-COLOR.CTB



LOCATION APPROVED UNDERGROUND STRUCTURES

SUPV. U/G STRUCTURES COMMITTEE _____ DATE _____


NOTE:
 LOCATION OF UNDERGROUND STRUCTURES AS SHOWN ARE BASED ON THE BEST INFORMATION AVAILABLE BUT NO GUARANTEE IS GIVEN THAT ALL EXISTING UTILITIES ARE SHOWN OR THAT THE GIVEN LOCATIONS ARE EXACT. CONFIRMATION OF EXISTENCE AND EXACT LOCATION OF ALL SERVICES MUST BE OBTAINED FROM THE INDIVIDUAL UTILITIES BEFORE PROCEEDING WITH CONSTRUCTION.

B.M. ELEV.			
CONSTRUCTION COMPLETION DATE: YYYY MM DD			
NO.	ISSUED FOR BID OP 634-2017	DATE	BY
		17/11/23	B.L.M.
	REVISIONS	DATE	BY

DILLON CONSULTING

DESIGNED BY: BLM	CHECKED BY: BLM
DRAWN BY: SCK	APPROVED BY: BLM
SCALE: HORIZONTAL AS SHOWN	RELEASED FOR CONSTRUCTION
VERTICAL AS SHOWN	DATE

CONSULTANT DRAWING NUMBER: E-06



THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT
 ENGINEERING DIVISION

2017 REHABILITATION OF PUBLIC WATER SERVICE
 OUTLETS: PAVEMENT WORKS, BUILDING SUPPLY AND REPAIRS, DEMOLITION AND ELECTRICAL
 ELECTRICAL - PREFABRICATED BUILDING PUBLIC WATER SERVICE
 OUTLET MCCARTHY STREET

ENGINEER'S SEAL

SHEET 12 OF 33
 CITY DRAWING NUMBER: D-14918