



668-2017 ADDENDUM 2

CONSTRUCTION OF PARKS STORAGE SHED – 85 FRASERS GROVE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: August 18, 2017
BY: Wins Bridgman
TELEPHONE NO. 204 488-3857 ext.29

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

Drawing Notes Revised

Revise: 668-2017_Drawing_G001-R0;
FLOOR TYPES – F1: FLOOR FINISHING NOTE Revise from “NEW CONCRETE FLOOR TO HAVE PIGMENTED POLYURETHANE (ON EPOXY BASE) FINISH. REFER TO SPECIFICATION SECTION 09 91 13 INTERIOR PAINTING; SUBSECTION 2.5.4 - INTERIOR PAINTING SYSTEMS FOR DETAILS” **To include Products: Sikafloor® 261CA as a Smooth Finish Coating & Sikafloor® Duochem 942 High-Gloss, Abrasion and UV Resistant, Smooth Urethane Coating for Floors and Walls**

Revise: 668-2017_Drawing_S003-R0;
Note no. 3 under the Foundation (CIP) Revise from: “CAST-IN-PLACE PILES TO BE A CLASS S-1 EXPOSURE (35 MPa @56d)” **to read “CAST-IN-PLACE PILES TO BE A CLASS S-1 EXPOSURE (32 MPa @56d)”**