



SYMBOL LEGEND	
(T)	THERMOSTAT
⊕	DUPLEX RECEPTACLE
⊕ _{GFI}	GFI DUPLEX RECEPTACLE
▬ _{BBH}	BASEBOARD HEATER
FE - 1	FIRE EXTINGUISHER
➔	DATA JACK

- GENERAL NOTES:**
- ALL OUTLETS INSIDE UNHEATED STORAGE SHED TO BE INSTALLED AT 1067mm A.F.F. UNLESS OTHERWISE NOTED
 - CONTRACTOR TO COORDINATE INSTALLATION OF ONE PHONE LINE INTO THE BUILDING – INCLUDING CONNECTION TO SERVICE PROVIDER NETWORK. LOCATE ONE (1) VOICE – DATA JACK IN ELECTRICAL ROOM. LOCATION TO BE DETERMINED BY CONTRACT ADMINISTRATOR.

ELECTRICAL FIXTURE SCHEDULE		
LABEL	FIXTURE	SPECIFICATION
BBH	BASEBOARD HEATER	DIMPLEX LINEAR CONVECTOR 2500W, 240V - SINGLE PHASE #LC6025W31 (1500mm LONG) OR APPROVED EQUAL IN ACCORDANCE WITH B7.
HD	HAND DRYER	DIMPLEX SERIES ONE COMMERCIAL HAND DRYER, 120V, 1450W, WHITE. #20001WH. OR APPROVED EQUAL IN ACCORDANCE WITH B7.
T	THERMOSTAT	DIMPLEX LINE VOLTAGE THERMOSTAT 240V, 7-DAY PROGRAMMABLE. OR APPROVED EQUAL IN ACCORDANCE WITH B7.

- GENERAL NOTES:**
- ALL THERMOSTATS TO BE GANGED TO ONE THERMOSTAT.

1 ELECTRICAL POWER PLAN
1 : 50