

EXTERIOR WALL TYPES

EW1	METAL CLADDING ON WOOD STUD FRAMING <ul style="list-style-type: none"> •22MM PREFINISHED 22 GA. CORRUGATED METAL CLADDING (1 COLOUR) •16x38MM VERTICAL FURRING STRIPS @ 406 MM O.C. •SPUN POLYOLEFIN AIR/WATER RESISTIVE BARRIER MEMBRANE •16MM GLASS FIBRE REINFORCED EXTERIOR SHEATHING •140MM WOOD STUD FRAMING @ 406MM O.C. •16MM TYPE-X GLASS FIBRE REINFORCED EXTERIOR SHEATHING; PAINTED •19MM G1S PLYWOOD INTERIOR SHEATHING TO 2438MM A.F.F (WHERE NOTED)
EW2	WOOD CLADDING ON WOOD STUD FRAMING <ul style="list-style-type: none"> •152MM HORIZONTAL TONGUE & GROOVE DOUGLAS FIR SIDING; CLEAR SEALED •16x38MM VERTICAL FURRING STRIPS @ 406 MM O.C. •SPUN POLYOLEFIN AIR/WATER RESISTIVE BARRIER MEMBRANE •16MM GLASS FIBRE REINFORCED EXTERIOR SHEATHING •140MM WOOD STUD FRAMING @ 406MM O.C. (FILL CAVITY W/ 140mm MINERAL WOOL BATT INSULATION) •6 MIL POLYETHYLENE VAPOUR BARRIER MEMBRANE •16MM ABUSE-RESISTANT GYPSUM WALL BOARD
EW3	POLYCARBONATE CLADDING ON WOOD STUD FRAMING <ul style="list-style-type: none"> •22MM CORRUGATED POLYCARBONATE CLADDING •16MM X 38MM (OR AS NOTED) PT WD FURRING •WOOD TRUSS FRAMING
EW4	GRADE BEAM <ul style="list-style-type: none"> •CEMENT PARGING ON GALVANIZED METAL LATH •BITUMINOUS DAMPROOFING •REINFORCED CONCRETE GRADE BEAM (REFER TO STRUCTURAL)
IW1	GWB ON WOOD STUD FRAMING (45 MIN FRR) <ul style="list-style-type: none"> •16MM ABUSE-RESISTANT GYPSUM WALL BOARD •140MM WOOD FRAMING @ 406MM O.C. •16MM ABUSE-RESISTANT GYPSUM WALL BOARD
IW2	GWB & G1S PLYWD ON WOOD STUD FRAMING (45 MIN FRR) <ul style="list-style-type: none"> •16MM ABUSE-RESISTANT GYPSUM WALL BOARD •6 mil POLYOLEFIN VAPOUR BARRIER •140MM WOOD FRAMING @ 406MM O.C. (FILL CAVITY W/ 140mm MINERAL WOOL BATT INSULATION) •16MM TYPE 'X' GLASS-FIBRE REINFORCED EXTERIOR SHEATHING •SPUN POLYOLEFIN AIR BARRIER •19MM G1S PLYWOOD SHEATHING TO FULL WALL HEIGHT; PAINTED

ROOF TYPES

R1	METAL ROOFING ON WOOD STUD FRAMING <ul style="list-style-type: none"> •22MM PREFINISHED 22 GA. STANDING SEAM METAL ROOFING •ADHERED WATERPROOF MEMBRANE •16MM PLYWOOD SHEATHING •WOOD TRUSS FRAMING
R2	INSULATED METAL ROOFING ON WOOD STUD FRAMING <ul style="list-style-type: none"> •22MM PREFINISHED 22 GA. STANDING SEAM METAL ROOFING •ADHERED WATERPROOF MEMBRANE •16MM PLYWOOD SHEATHING •WOOD TRUSS FRAMING •279mm MINERAL WOOL BATT INSULATION •6 mil POLYOLEFIN VAPOUR BARRIER •16MM ABUSE-RESISTANT GYPSUM WALL BOARD

FLOOR TYPES

F1	SLAB ON GRADE <ul style="list-style-type: none"> •REINFORCED CONCRETE SLAB ON GRADE (REFER TO STRUCTURAL) •UNDERSLAB VAPOUR BARRIER MEMBRANE •COMPACTED SAND •COMPACTED BASE (REFER TO STRUCTURAL) •COMPACTED SUB-BASE (REFER TO STRUCTURAL)
-----------	---

FLOOR FINISH NOTE:

- NEW CONCRETE FLOOR TO HAVE PIGMENTED POLYURETHANE (ON EPOXY BASE) FINISH. REFER TO SPECIFICATION SECTION 09 91 13 INTERIOR PAINTING; SUBSECTION 2.5.4 - INTERIOR PAINTING SYSTEMS FOR DETAILS

GENERAL NOTES:

- ALL GYPSUM BOARD IN WASHROOMS & COUNTER AREA TO BE 5/8" MOISTURE-RESISTANT "GREEN BOARD" TYPE **

-ALL WASHROOM STUD PARTITIONS TO HAVE ACOUSTIC MINERAL FIBRE BATT INSULATION IN STUD CAVITY

** WHERE 16mm 'GREEN BOARD' TYPE, MOISTURE-RESISTANT GWB IS USED, IT IS INTENDED TO REPLACE THE ABUSE-RESISTANT GWB; NOT INSTALLED AS AN ADDITIONAL LAYER.

SYMBOL LEGEND

	SECTION DETAILS & BUILDING SECTION TAG
	CALLOUT TAG
	ELEVATION TAG
	GLAZING ELEVATION TAG
	LEVEL TAG
	SPOT ELEVATION
	WALL TAG
	FLOOR TAG
	ROOF TAG
	DOOR TAG
	GRID LINE
	ROOM TAG
	INDICATES GLAZING
	BREAK LINE
	ACTUATOR
	CENTRE LINE
	NORTH ARROW