



MECHANICAL EQUIPMENT SCHEDULE		
LABEL	FIXTURE	SPECIFICATION
HRV-1	HEAT RECOVERY VENTILATOR	LIFEBREATH 95 MAX, SET TO 50 CFM, OR APPROVED EQUAL IN ACCORDANCE WITH B7. INCLUDING CONCENTRIC/ DUAL HOOD; #99-190 (5")
DH-1	INLINE DUCT HEATER	THERMOLEC STANDARD FRESH-AIR & ZONE HEATER, #TER-5-1120 (1KW), OR APPROVED EQUAL IN ACCORDANCE WITH B7.
S-1	SUPPLY GRILLE	E.H. PRICE DOUBLE DEFLECTION SUPPLY GRILLE C/W STEEL DAMPER, #520D-F-SDF-L-A-B12, 254mm x 150mm. OR APPROVED EQUAL IN ACCORDANCE WITH B7.
R-1	RETURN GRILLE	E.H. PRICE FIXED LOUVER, 45° - #520 F-L-A-B12, 254mm x 150mm, C/W DUCT ADAPTER TO CONNECT TO RETURN DUCT. OR APPROVED EQUAL IN ACCORDANCE WITH B7.
EF-1	EXHAUST FAN	GREENHECK EXHAUST FAN #SE1-12-432-VG, DISCHARGE HOOD C/W BIRDSCREEN, INLET SAFETY SCREEN & BDD. OR APPROVED EQUAL IN ACCORDANCE WITH B7.
F/A-1	INTAKE LOUVER	750x500 O/A INTAKE LOUVER C/W BIRD SCREEN. LOUVER TO BE EH PRICE ZE445. INTAKE C/W UPTURNED ELBOW OPEN ENDED AT HIGH LEVEL (OR APPROVED EQUAL IN ACCORDANCE WITH B7).

GENERAL NOTES:

1. PROVIDE A SUPPLY & RETURN BALANCE DAMPER IF NOT INTEGRATED WITHIN THE HRV UNIT.
2. COLOUR OF LOUVERS TO BE CONFIRMED BY ARCHITECT.
3. CONTRACTOR TO COORDINATE ALL CONTROLS FOR HEATING & COOLING.



1 MECHANICAL HVAC PLAN
1 : 50